WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51596
Permit No.
Basin 163

NOTICE OF INTENT NO. 15229

1. OWNER JACK DUNN
MAILING ADDRESS
ADDRESS AT WELL LOCATION OTTAWA & GYPSUM
SANDY VALLEY

2. LOCATION NW¼/NW¼ SE¼/SW¼ Sec. 24 T. 24 N/S R. 56 E. CLARK County
PERMIT NO. (Issued by Water Resources) | Parcel No. 580-210-065 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| ROCK & GRAVEL | | 0 | 4 | 4 |
| CLAY & GRAVEL | | 4 | 85 | 81 |
| CEMENTED ROCK & GRAVEL | | 85 | 95 | 10 |
| CLAY & GRAVEL | | 95 | 115 | 20 |
| ROCK & GRAVEL | W.B | 115 | 145 | 30 |

Date started 5-23, 1996
Date completed 5-28, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 145 Feet Depth Cased 145 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From (Feet) | To (Feet) |
|---|---|---|
| 12¼ | 0 | 145 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 5/8 | 16.94 | .188 | 0 | 145 |
| | | | | |
| | | | | |

Perforations:
Type perforation FACTORY SAW CUT
Size perforation ⅛ INCH BY 3 INCH
From 145 feet to 125 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 145 feet to 50 feet

9. WATER LEVEL
Static water level 108 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BADGET DRILLING CO (Contractor)
Address P.O. BOX 3505 (Contractor)
PAHRUMP NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 40020
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1523
Signed (By driller performing actual drilling on site or contractor)
Date 5-29-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627