

OFFICE USE ONLY  
 Log No. 51614  
 Permit No. \_\_\_\_\_  
 Basin. 212



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17522

1. OWNER Mark Escoto ADDRESS AT WELL LOCATION N.W. corner Haven & Chartan  
 MAILING ADDRESS 6670 S. Maryland Pkwy. Las Vegas, NV 89119 1106 S HAVEN ST  
 2. LOCATION NW 1/4 SW 1/4 Sec. 33 T. 22 N/S R. 61 E Clark County  
 PERMIT NO. File 1 Page 15 Lot 20 177-33-303-005 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

| Material    | Water Strata | From | To  | Thickness |
|-------------|--------------|------|-----|-----------|
| Silt & rock |              | 0    | 33  |           |
| Rock & clay |              | 33   | 168 |           |
| Clay        |              | 168  | 172 |           |
| Rock & clay |              | 172  | 207 |           |
| Clay        |              | 207  | 216 |           |
| Rock & clay |              | 216  | 403 |           |

8. WELL CONSTRUCTION  
 Depth Drilled 403 Feet Depth Cased 403 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 9 7/8 Inches 0 Feet 403 Feet  
 To \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6 5/8              | 12.94               | .188                    | +2          | 403       |

Perforations:  
 Type perforation machine  
 Size perforation 1/8" X 2 1/2"  
 From 294 feet to 314 feet  
 From 374 feet to 394 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 53  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 53 feet to 403 feet

9. WATER LEVEL  
 Static water level 199 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Briner Drilling Inc. Contractor  
 Address 555 N. Parkson Rd. Henderson, NV 89015 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 6294A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1338  
 Signed M. D. Briner By driller performing actual drilling on site or contractor  
 Date May 16, 1996



Date started 5-4 1996  
 Date completed 5-7 1996

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
|        |                               |              |
|        |                               |              |
|        |                               |              |
|        |                               |              |