

WHITE - DIVISION OF WATER RESOURCES  
 CANARY - CLIENT'S COPY  
 PINK - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT

OFFICE USE ONLY  
 Log No. 51639  
 Permit No. \_\_\_\_\_  
 Basin 230

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17902

1. OWNER BRITTAN, SAM ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_  
AMARGOSA, NV 89041 BETTLES RD

2. LOCATION SE 1/4 NW 1/4 Sec. 7 T 17S N/S R 49E E NYE County \_\_\_\_\_  
 PERMIT NO. 19-401-11

Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND & GRAVEL		0	30	30
CEMENTED GRAVEL		30	45	15
CLAY & GRAVEL		45	65	20
CEMENTED GRAVEL		65	70	5
CLAY & GRAVEL		70	85	15
CEMENTED GRAVEL	TR	85	90	5
CLAY & GRAVEL		90	125	35
CALICHE	WB	125	128	3
CLAY & GRAVEL		128	135	7
CALICHE	WB	135	140	5

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
 From 12.25 Inches To 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE


Size O.D. (Inches)	Weight/Fl. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8.625	16.94	.188	0	140

Perforations:  
 Type perforation FACTORY SAW CUT  
 Size perforation 1/8 X 3

From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 140 feet



Date started 5/13/96 . 19\_\_  
 Date completed 5/17/96 . 19\_\_

9. WATER LEVEL  
 Static water level 93 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Great Basin Drilling Co. Contractor  
 Address P O BOX 4220 Contractor  
PAHRUMP, NV 89041

Nevada contractor's license number issued by the State Contractor's Board 30880  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642

Signed Thomas Dan  
 By driller performing actual drilling on-site or contractor  
 Date 5/29/96