


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17903

1. OWNER **MOLAMOY, EUGENE** ADDRESS AT WELL LOCATION 2681 TONYA DR
 MAILING ADDRESS _____
PAHRUMP, NV 89041

2. LOCATION SE 1/4 NW 1/4 Sec. 30 T 19S N/S R 53E E NYE _____ County _____
 PERMIT NO. 29-481-08 VALLEY VIEW ACRES
 Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	35	35
CALICHIE		35	37	2
CLAY		37	69	32
CALICHIE	WB	69	73	4
CLAY		73	106	33
CALICHIE	WB	106	109	3
CLAY		109	126	17
CALICHIE	WB	126	128	2
CLAY		128	137	9
CALICHIE	WB	137	140	3

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From 12.25 Inches To 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8.625	16.94	.188	0	140

Perforations:
 Type perforation **FACTORY SAW CUT**
 Size perforation 1/8 X 3

From 100 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 50
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 48 feet below land surfac
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Great Basin Drilling Co.** Contractor

Date started 5/13/96 . 19__
 Date completed 5/17/96 . 19__

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

Address **P O BOX 4220** Contractor
PAHRUMP, NV 89041

Nevada contractor's license number issued by the State Contractor's Board **30880**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1642**

Signed Thomas Damm
 By driller performing actual drilling on-site or contractor
 Date 5/29/96

