WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51659
Permit No.
Basin 0172

NOTICE OF INTENT NO. 28344

1. OWNER Pegasus
MAILING ADDRESS P.O. Box 330
Imlay, NV 89418

ADDRESS AT WELL LOCATION I-80 Exit 138 Well #1 replacement
Imlay, NV 89418

2. LOCATION SE ¼ NW ¼ Sec. 3 T. 31 N/S R. 33 E. Pershing County
PERMIT NO. 57097 & 48998 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay & cobbles		0	200	200
bolders & clay		200	530	330
consolidated bedrock		530	545	15
fractured bedrock		545	780	235
(lost circulation)				

Date started April 15, 19 96
Date completed April 26, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
airlift	approx. 700		10 hr.

8. WELL CONSTRUCTION
Depth Drilled 780 Feet Depth Cased 755 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
21	Inches	0	Feet	60	Feet
15½	Inches	60	Feet	755	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16		.250	+1	60
10 3/4		.250	+2	455

Perforations:
Type perforation full-flow louvered
Size perforation
From 455 feet to 755 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From surface feet to 755 feet

9. WATER LEVEL
Static water level 150 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 200+ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ~~Humboldt Drilling & Pump Co., Inc.~~ (Contractor)
Address 4675 W. Winnemucca Blvd. 109-13 (Contractor)
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713

Signed [signature]
By driller performing actual drilling on site or contractor
Date 4-29-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627