PZ-95-11

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51701
Permit No.
Basin OGL

NOTICE OF INTENT NO. 32515

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NEVADA 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION SE ¼ SE ¼ Sec 19 T 36 (N) S R 50 E EUREKA County
PERMIT NO. MO-441A (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CARLIN		0	160	160
CARLIN & GRAVEL		160	240	80
GRAVEL & CLAYS		240	280	40
BED ROCK		280	340	60

NOTE: TRANSDUCERS PLACED IN HOLE - GRAVEL PACKED AND SEPERATED BY BENTONITE HOLE PLUG

Date started JAN 22, 1996
Date completed JAN 27, 1996

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		1

8. WELL CONSTRUCTION
Depth Drilled 340 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12-1/4 Inches	0 Feet	21 Feet	
6-1/8 Inches	21 Feet	340 Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7	20	.250	0	21
1-1/2	3	SCH 80	0	98

Perforations:
Type perforation DRILLED
Size perforation 1/8"
From 98 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 340 feet

9. WATER LEVEL
Static water level 38 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 64 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1410
Signed JOHN VIERGUTZ (By driller performing actual drilling on site or contractor) John Viergutz
Date FEBRUARY 2, 1996

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627