WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51717
Permit No.
Basin

NOTICE OF INTENT NO. 13480

1. OWNER Steve Baldwin
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION NE ¼ SW ¼ Sec. 14 T. 22 N/S R. 60 E. Clark County
PERMIT NO. 176143 01019
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sandy Clay | | 0 | 4 | 4 |
| Consolated Gravel | | 4 | 140 | 136 |
| Cemented Gravel | | 136 | 400 | 264 |
| Clay + Gravel | | 400 | 490 | 90 |
| Gravel + Boulders | | 490 | 580 | 90 |

DCNR/DWR JUN 18 1996 LAS VEGAS OFFICE

Date started 5/6, 1996
Date completed 5/17, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| air Lifted | | |
| 40/45 Gpm | | |

8. WELL CONSTRUCTION
Depth Drilled 580 Feet Depth Cased 580 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 9 7/8 Inches | 0 Feet | 580 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | | .188 | 1 1/2 | 580 |

Perforations:
Type perforation Torch
Size perforation 1/4 X 10
From 500 feet to 580 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 580 feet

9. WATER LEVEL
Static water level 440 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality ok

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Mitchell Ent
Contractor
Address 450 S Arville #262
Contractor
Las Vegas NV 89103
Nevada contractor's license number issued by the State Contractor's Board 42266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1475
Signed Dean Mitchell
By driller performing actual drilling on site or contractor
Date 5/17/96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627