


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT

OFFICE USE ONLY  
 Log No. 51729  
 Permit No. \_\_\_\_\_  
 Basin 162



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17900

1. OWNER REED, WILLIAM ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_  
PAHRUMP, NV 89041 1221 FALCON

2. LOCATION SE \_\_\_\_\_ 1/4 SW \_\_\_\_\_ 1/4 Sec. 35 \_\_\_\_\_ T 20S \_\_\_\_\_ N/S R 53E \_\_\_\_\_ E NYE \_\_\_\_\_ County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ 41-181-04 \_\_\_\_\_ CALVADA \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	23	23
CALICHIE		23	31	8
CLAY		31	67	36
CALICHIE	WB	67	70	3
CLAY		70	91	21
CALICHIE	WB	91	96	5
CLAY		96	114	18
CALICHIE	WB	114	116	2
CLAY		116	127	11
CALICHIE	WB	127	131	4
CLAY		131	140	9

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
12.25 Inches 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8.625	16.94	.188	0	140

Perforations:  
 Type perforation FACTORY SAW CUT  
 Size perforation 1/8 X 3

From <u>100</u>	feet to <u>120</u>	feet
From _____	feet to _____	feet
From _____	feet to _____	feet
From _____	feet to _____	feet
From _____	feet to _____	feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 \_\_\_\_\_  
 Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL  
 Static water level 58 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Great Basin Drilling Co. Contractor  
 Address P O BOX 4220 Contractor  
PAHRUMP, NV 89041  
 Nevada contractor's license number issued by the State Contractor's Board 30880  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642

Signed Thomas Dan  
 By driller performing actual drilling on-site or contractor  
 Date 5/22/96

Date started 5/7/96, 19\_\_\_\_  
 Date completed 5/10/96, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

