


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY

Log No. **51732**
 Permit No. _____
 Basin **162**



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **17906**

1. OWNER **BALLAMY, DORTHY** ADDRESS AT WELL LOCATION **2861 WILSON**
 MAILING ADDRESS _____
PAHRUMP, NV 89041

2. LOCATION **NW 1/4 SW 1/4 Sec. 18 T 20S** N/S **R 53E E NYE** County _____
 PERMIT NO. **36-201-11E** **CHARLSTON PARK RANCHOS**
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|----------|--------------|------|-----|------------|
| CLAY | | 0 | 41 | 41 |
| CALICHIE | | 41 | 43 | 2 |
| CLAY | | 43 | 69 | 26 |
| CALICHIE | WB | 69 | 72 | 3 |
| CLAY | | 72 | 101 | 29 |
| CALICHIE | WB | 101 | 103 | 2 |
| CLAY | | 103 | 123 | 20 |
| CALICHIE | WB | 123 | 125 | 2 |
| CLAY | | 125 | 134 | 9 |
| CALICHIE | WB | 134 | 140 | 6 |

8. WELL CONSTRUCTION
 Depth Drilled **140** Feet Depth Cased **140** Feet

HOLE DIAMETER (BIT SIZE)
 From **0** To **140**
12.25 Inches **0** Feet **140** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 8.625 | 16.94 | .188 | 0 | 140 |

Perforations:
 Type perforation **FACTORY SAW CUT**
 Size perforation **1/8 X 3**
 From **100** feet to **120** feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **50** _____
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From **50** feet to **140** feet

9. WATER LEVEL
 Static water level **48** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Great Basin Drilling Co.** Contractor
 Address **P O BOX 4220** Contractor
PAHRUMP, NV 89041
 Nevada contractor's license number issued by the State Contractor's Board **30880**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1642**
 Signed **Thomas D...**
 By driller performing actual drilling on-site or contractor
 Date **5/29/96**

Date started **5/13/96**, 19____
 Date completed **5/17/96**, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
| | | |
| | | |
| | | |
| | | |
| | | |

