

OFFICE USE ONLY
 Log No. 51739
 Permit No. _____
 Basin. 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16311

1. OWNER BROADBENT & ASSOCIATES ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 833 NEVADA HIGHWAY, SE 1/4 ADDRESS 2083 E. FREMONT ST.
BOULDER CITY, NV 89005 Las Vegas, NV
 2. LOCATION SE 1/4 SE 1/4 Sec. 35 T. 20 N. S. R. 61 E Clark County
 PERMIT NO. MD-2505B 139-35-802-007 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE S-1
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Silty Sand</u>		<u>0</u>	<u>1 1/2</u>	<u>1 1/2</u>
<u>Silty clay</u>		<u>1 1/2</u>	<u>6 1/2</u>	<u>5</u>
<u>Silty sand w/ clay</u>		<u>6 1/2</u>	<u>20</u>	<u>13 1/2</u>
	<u>7 1/2</u>			

8. WELL CONSTRUCTION
 Depth Drilled 20 Feet Depth Cased 20 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 0 Feet 20 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>	<u>0.64</u>	<u>0.218</u>	<u>0</u>	<u>20</u>

Perforations:
 Type perforation factory slot
 Size perforation 0.020
 From 17 1/2 feet to 19 1/2 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 0-15 1/2' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 16 1/2 feet to 20 feet

9. WATER LEVEL
 Static water level 7.83 feet below land surface
 Artesian flow _____ G.P.M. _____ M.S.I.
 Water temperature _____ °F Quality _____

Date started February 1, 1996
 Date completed February 1, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name KENT GROOVER Contractor
 Address 731 PILOT RD, STE H
LAS VEGAS, NV 89119
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1953
 Signed [Signature] by driller performing actual drilling on site or contractor
 Date 6-14-96