WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51752
Permit No.
Basin 212

NOTICE OF INTENT NO. 17557

1. OWNER City of Las Vegas
MAILING ADDRESS 400 STEWART AVE LAS VEGAS NV 89101
ADDRESS AT WELL LOCATION 401 Las Vegas Blvd S. Las Vegas, NV

2. LOCATION NW ¼ SE ¼ Sec. 34 T. 20 ☒S R. 61 ☐E Clark County
PERMIT NO. M02401C (Issued by Water Resources) | ~~UNKNOWN~~ 139-34-303-001 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE FC-3
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| FILL | | 0 | ½ | ½ |
| SILTY CLAY | | ½ | 12 | 11½ |
| CALICHE | | 12 | 16 | 4 |
| | 13½ | | | |
| SILTY CLAY PART. CEMENTED | | 16 | 35 | 19 |

Date started JUNE 6, 19 96
Date completed JUNE 6, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 35 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From (Feet) | To (Feet) |
|---|---|---|
| 8 | 0 | 35 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2.375 | 0.64 | 0.218 | 0 | 35 |
| | | | | |

Perforations:
Type perforation factory slot
Size perforation 0.020
From 5 feet to 35 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 1 ft.
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 3 feet to 20 feet

9. WATER LEVEL
Static water level 13.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name TOM HIGH
Address 731 PILOT RD, STE H (Contractor)
Las Vegas, NV 89119 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1869
Signed Tom High (By driller performing actual drilling on site or contractor)
Date 6-14-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627