


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 51805
 Permit No. _____
 Basin 162



Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17879

WRITE ON BACK

1. OWNER HETTINGER, ART ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____
PAHRUMP, NV 89041 731 W. FAIRBANKS

2. LOCATION SE 1/4 SW 1/4 Sec. 9 T 20S N/S R 53E E NYE County
 PERMIT NO. 35-183-05 CAL-VEGAS RANCHOS
 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	23	23
CALICHE		23	26	3
CLAY		26	68	42
CALICHE	WB	68	73	5
CLAY		73	94	21
CALICHE	WB	94	96	2
CLAY		96	126	29
CALICHE	WB	126	127	2
CLAY		127	136	9
CALICHE	WB	136	140	4

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
12.25 Inches 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8.58</u>	<u>18.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation FACTORY SAW CUT
 Size perforation 1/8 X 3

From 100 feet 120 feet
 From _____ feet _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 60 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 60 feet 140 feet

9. WATER LEVEL
 Static water level 62 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Great Bash Drilling Co. Contractor
 Address PO BOX 4220 Contractor
PAHRUMP, NV 89041

Nevada contractor's license number issued by the State Contractor's Board 30920
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1842

Signed Thomas De...
 By driller performing actual drilling on-site or contractor
 Date 5/4/96

Date started 4/24/98, 19____
 Date completed 4/26/98, 19____

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

