WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51837
Permit No.
Basin 212

NOTICE OF INTENT NO. 16031

1. OWNER Sanos Hotel + Casino
MAILING ADDRESS 3355 S. Las Vegas Blvd
Las Vegas NV
ADDRESS AT WELL LOCATION 3355 S. Las Vegas Blvd
L.V. NV

2. LOCATION NW ¼ SW ¼ Sec. 16 T. 21 N/S R. 61 E. Clark County
PERMIT NO. MO-2711 (Issued by Water Resources) 162-16-301-008-006-091 (Parcel No.) Subdivision Name

3. WORK PERFORMED: [X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE: [ ] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE: [ ] Cable [ ] Rotary [ ] RVC [X] Air [X] Other

6. WELL #11 LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill Matl		0	1	1
Sandy Gravel w/Silt		1	2.5	1.5
Brn Silty Sand + Gravel		2.5	4	1.5
Brn Sandy Gravel w/Silt		4	5.5	1.5
Brn Silty Sand Gravel		5.5	6.5	1
Clayey Sand + Gravel Lt. Brn		6.5	8	1.5
Sandy Clay Lt. Br.		8	9	1
Silty Clay Lt. Brn		9	10	1
Caliche Lt Brn		10	11.5	1.5
Sandy Clay, Gravel Lt. Brn	▽	11.5	14.5	3
Silty Clay w/ Caliche Gr. Lt. Brn.		14.5	20.5	6
Caliche		20.5	22	1.5
Lt. Brn. Sandy Clay		22	23	1
Caliche		23	26	3
Lt. Brn Sandy Clay w/Cal. Gravel		26	27	1
Caliche		27	30	3

RECEIVED MAY 15 1996 DIVISION OF WATER RESOURCES

Date started April 22, 1996
Date completed Apr. 22, 1996

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6"	Inches	0 Feet	30 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 3/8			0	10

Perforations:
Type perforation Slotted
Size perforation .020
From 10 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 9
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 9 feet to 20 feet

9. WATER LEVEL
Static water level 13.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Terracon Consultants (Contractor)
Address 4343 S. Polaris (Contractor)
Las Vegas NV
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2017
Signed Kenneth A. Kutania (By driller performing actual drilling on site or contractor)
Date 5-10-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627