

OFFICE USE ONLY  
Log No. 51860  
Permit No. \_\_\_\_\_  
Basin. 105

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24747

1. OWNER GARY HILL ADDRESS AT WELL LOCATION 1731 SUNSET  
MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE

2. LOCATION SW 1/4 SE 1/4 Sec. 35 T. 13 N. R. 20 E. DOUGLAS County  
PERMIT NO. 23-560-04 WILDFLOWER Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY / GRAVEL		0	7	7
CEMENTED GRAVEL / GRAVEL		7	14	7
SANDY CLAY		14	19	5
CEMENTED GRAVEL		19	33	14
SANDY CLAY		33	38	5
SANDY CLAY / GRAVEL		38	51	13
CLAY		51	59	8
SAND / GRAVEL		59	122	63
SANDY CLAY / GRAVEL		122	146	24
SAND / GRAVEL		146	152	6
SANDY CLAY / GRAVEL		152	164	12
SAND / GRAVEL		164	179	15
SANDY CLAY / GRAVEL		179	221	42
SAND GRAVEL	✓	201	233	32
SANDY CLAY		233	240	7

8. WELL CONSTRUCTION  
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)  
From To  
10 5/8 Inches 0 Feet 100 Feet  
9 7/8 Inches 100 Feet 240 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>240</u>

Perforations:  
Type perforation FACTORY SLOTTED  
Size perforation 1/8 x 3  
From 220 feet to 240 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 100  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 100 feet to 240 feet

9. WATER LEVEL  
Static water level 5.5 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature COLD °F Quality GOOD

Date started 5-15, 1996  
Date completed 5-17, 1996

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25+</u>	<u>-</u>	<u>1</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name EDDCO EXPLORATION, INC Contractor  
Address 7780 CURRY RD Contractor  
FALLON, NV 89406  
Nevada contractor's license number 27673  
issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1997  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 5-17-96