



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24737

1. OWNER RED SUN + SAND DEVELOPMENT ADDRESS AT WELL LOCATION 924 FOOTHILL RD.
 MAILING ADDRESS MINDEN, NV GARDNERVILLE

2. LOCATION SE 1/4 NE 1/4 Sec. 15 T. 12 N. R. 19 E. DOUGLAS County
 PERMIT NO. 19-170-02 Parcel No. _____ Subdivision Name FOOTHILL

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>DUPIE'S - COBEL'S</u>		<u>0</u>	<u>8</u>	<u>8</u>
<u>DG</u>		<u>8</u>	<u>23</u>	<u>25</u>
<u>HARD DG</u>		<u>23</u>	<u>30</u>	<u>7</u>
<u>DG</u>		<u>30</u>	<u>54</u>	<u>24</u>
<u>COBEL'S, GRANIT</u>		<u>54</u>	<u>58</u>	<u>4</u>
<u>DG</u>		<u>58</u>	<u>78</u>	<u>20</u>
<u>COBEL'S</u>		<u>78</u>	<u>100</u>	<u>22</u>
<u>DG</u>		<u>100</u>	<u>105</u>	<u>5</u>
<u>COBEL'S</u>		<u>105</u>	<u>106</u>	<u>1</u>
<u>DG</u>		<u>106</u>	<u>125</u>	<u>14</u>
<u>GRANIT</u>		<u>125</u>	<u>127</u>	<u>2</u>
<u>DG</u>		<u>127</u>	<u>169</u>	<u>41</u>
<u>SANDY CLAY, GRAVEL</u>		<u>169</u>	<u>173</u>	<u>4</u>
<u>HARD DG</u>		<u>173</u>	<u>196</u>	<u>23</u>
<u>DG</u>		<u>196</u>	<u>240</u>	<u>44</u>

8. WELL CONSTRUCTION
 Depth Drilled 240 Feet Depth Cased 240 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 240 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>240</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 1/8 X 3
 From 220 feet to 240 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 240 feet

9. WATER LEVEL
 Static water level 135 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD Contractor
FALLON, NV 89406
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1997
7535
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 5-15-96

Date started 5-7, 1996
 Date completed 5-14, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>AIR</u>	<u>20+</u>	<u>-</u>	<u>3</u>