

OFFICE USE ONLY  
Log No. 51876  
Permit No. 102  
Basin 102

I

NOTICE OF INTENT NO. 24744

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER RON WALTER ADDRESS AT WELL LOCATION PIKE CUT RD  
MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE

2. LOCATION NW 1/4 SE 1/4 Sec. 1 T 11 N 21 E DOUGLAS County  
PERMIT NO. 35-080-35 PIKE CUT MTS Subdivision Name  
Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other PIPED

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy clay w/ gravel		0	4	4
Brn dyorite 1/2" fract		4	90	86
gn dyorite		90	170	80
Brn dyorite "		170	197	27
Sandy clay		197	206	9
Sandy clay w/ sm gravel		206	221	15
grn dyorite 1/2" fract		221	240	19
Sandy clay w/ gravel		240	290	50
gn clay w/ shale		290	318	28
fract shale		318	335	17
shale		335	341	6
fract shale	/	341	375	34
shale some fract		375	418	43
fract shale	/	418	438	20
shale		438	445	7
fract. shale	/	445	476	31

8. WELL CONSTRUCTION  
Depth Drilled 476 Feet Depth Cased 476 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0	50
9 7/8 Inches	50	375
5 3/4 Inches	375	476

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	0	375
5	10	.188	370	476

Perforations:  
Type perforation FACTORY SLOTTED  
Size perforation 3 x 1/8 T.C.  
From 310 feet to 375 feet  
From Factory 4" 355 feet to 375 feet  
From T.C. 5" 375 feet to 476 feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 50 feet to 476 feet

Date started 4-18 1996  
Date completed 5-14 1996

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>A112</u>	<u>5+</u>	<u>-</u>	<u>4</u>

9. WATER LEVEL  
Static water level 365 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name EDDIE EXPLORATION, INC. Contractor  
Address 7780 CURRY RD. Contractor  
FALLON, NV 89406  
Nevada contractor's license number issued by the State Contractor's Board 27673  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535  
Signed Arad W. Pineda  
By driller performing actual drilling on site or contractor  
Date 5-15-96