WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51888
Permit No.
Basin 104

NOTICE OF INTENT NO. 28475

1. OWNER Rick Champelovier
MAILING ADDRESS P.O. Box 3598 Stateline NV. 89449
ADDRESS AT WELL LOCATION #6 Canyon Dr. Carson City NV 89701

2. LOCATION SW ¼ SW ¼ Sec. 13 T. 15 N/S R. 19 E. Carson County
PERMIT NO. (Issued by Water Resources) Parcel No. 7-131-25 Subdivision Name Kings Canyon Sub.

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sands		0	47	47
Brown Clay Zone		47	50	3
Coars Dk Sands		50	110	60
Coarse Gravels A Few Boulders	X	110	165	55
Hard Granite with Fractures	XX	165	190	25

Date started 6-13, 1996
Date completed 6-20, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
18	80	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 190 Feet Depth Cased 190 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches	0 Feet	105 Feet	
9 7/8 Inches	105 Feet	190 Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	190

Perforations:
Type perforation Mill Slot
Size perforation 3 x 3/32
From 150 feet to 190 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100 feet to 190 feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow G.P.M. 18 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A. H Pump Co. (Contractor)
Address 5551 Hwy 60 E #3 Carson City NV. 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed (By driller performing actual drilling on site or contractor)
Date 6-21-96

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627