

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 3114  
SW CORNER  
OF HWY 50 E AND GRAVES LANE

1. OWNER HONE FAMILY TRUST ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS PO Box 1956 \_\_\_\_\_  
MINDEN NV 89423 \_\_\_\_\_  
 2. LOCATION SE 1/4 NW 1/4 Sec. 10 T 15 \_\_\_\_\_  
S R 20 E CARSON CITY County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ CATLEDGE Subdivision Name \_\_\_\_\_  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
INSTALL 8" PIPE OVER 6" TO 6' BELOW GL, DIRT CONTRACTOR PULLED TOP OF 6" OFF, DROPPED PUMP IN WELL, PUT 1-2 SK OF REB-MIX W BAGS IN WELL, COVERED UP, DC CAME BACK DUG HOLE AT WELL & EXPOSED 6" PIPE.				
CLEANED WELL TO TOP OF DROP PIPE, PULLED DP + CABLE, PUMP BROKE OFF, DRILLED/PUSHED PUMP TO 100 FT STOPPED.				
RIPPED CASING, WELL COLLAPSED (OF COURSE!) DRILLED WELL TO 100', PREMIXED 27 SK OF CEMENT FROM 94' TO GL, ADDED ONE MORE AT GL.				

8. WELL CONSTRUCTION  
 Depth Drilled 120 Feet Depth Cased 120 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal \_\_\_\_\_  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 6/19 1996  
 Date completed 6/21 1996

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL  
 Static water level: \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name NEVADA DRILLING, INC Contractor  
 Address 75 LEWERS CRT RD Contractor  
CARSON CITY, NV 89701  
 Nevada contractor's license number 13697A  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1790  
 Division of Water Resources, the on-site driller  
 Signed Joe Leish  
 By driller performing actual drilling on site or contractor  
 Date 6/24/96