WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51896
Permit No.
Basin 179

NOTICE OF INTENT NO. 28892

1. OWNER Joe Maze
MAILING ADDRESS HC Box 32014
Ely, NV 89301

ADDRESS AT WELL LOCATION 5 Miles North of Ely
Lot 120

2. LOCATION NW ¼ NW ¼ Sec. 22 T. 17 N/S R. 63 E. White Pine County
PERMIT NO. (Issued by Water Resources) 5-601-05 (Parcel No.) Cross Timbers (Subdivision Name)

3. WORK PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[x] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [x] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	6	6
Gravel		6	10	4
Clay & Gravel		10	15	5
Gravel		15	45	30
Clay & Gravel		45	50	5
Gravel		50	55	5
Clay & Gravel		55	60	5
Gravel		60	80	20
Clay & Gravel		80	85	5
Sand & Gravel	x	85	105	20
Clay & Gravel		105	120	15
Sand & Gravel	x	120	140	20
Clay & Gravel		140	155	15
Sand & Gravel	x	155	165	10
Clay & Gravel		165	180	15

Date started April 9, 19 96
Date completed April 10, 19 96

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [x] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
150	65	1

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	180 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	180

Perforations:
Type perforation Factory
Size perforation 1/8" x 2½" 6 rows
From 80 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [x] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [x] Poured
Seal Type: [ ] Neat Cement [x] Cement Grout [ ] Concrete Grout

Gravel Packed: [x] Yes [ ] No
From 50 feet to 180 feet

9. WATER LEVEL
Static water level 105 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Avenue (Contractor)
Ely, Nevada 89301

Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641

Signed Jerald D. Christiansen (By driller performing actual drilling on site or contractor)
Date April 26, 1996

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627