

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24734

1. OWNER MR. GERHARDT ADDRESS AT WELL LOCATION 1589 BARKER CT GARDNERVILLE
 MAILING ADDRESS GARDNERVILLE, NV

2. LOCATION NE 1/4 NW 1/4 Sec 32 T 13 R 21 E DOUGLAS County FISH SPRINGS
 PERMIT NO. 23-170-14 Parcel No. _____ Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy clay w/ cobbles		0	31	31
gravel w/ sandy clay		31	120	89
Sandy clay / coarse sand		120	200	80
course sand	/	200	203	3
Sandy clay		203	215	12
course sand some sil.	/	215	221	6
Sandy clay		221	240	19
course sand	/	240	242	2
Sandy clay		242	250	8
course sand	/	250	251	1
Sandy clay		251	259	8
course sand	/	259	264	5
Sandy clay		264	265	1

8. WELL CONSTRUCTION
 Depth Drilled 265 Feet Depth Cased 265 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 5/8 Inches _____ Feet 50 Feet
9 7/8 Inches 50 Feet 265 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>265</u>

Perforations:
 Type perforation FACTORY SLOT + TORCH CUT
 Size perforation 1/8 x 3
 From factory 200 feet to 220 feet
 From J.L. 220 feet to 265 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 50 Cement Grout
 Placement Method: Pumped Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 265 feet

Date started 3-22 1996
 Date completed 4-5 1996

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25+</u>	<u>—</u>	<u>2</u>

9. WATER LEVEL
 Static water level 80 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD Contractor
FALLOON, NV 89406
 Nevada contractor's license number 27673 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
 Signed Donald W. Rheinbold
 By driller performing actual drilling on site or contractor
 Date 4-5-96