

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22880

1. OWNER WILLA SIMPSON/JEFFREY PADDOCK ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 755 Stoker 125 Alpha Butte  
Reno, Nevada 89503 Reno, Nevada 89506

2. LOCATION SW 1/4 SE 1/4 Sec. 19 T. 22N N/S R. 19E E. Washoe County  
 PERMIT NO. 79-352-01 Red Rock Estates #53  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy top soil		0	2	2
Sandy brown clay		2	62	60
Soft zone (no water)		62	63	1
Brown sandy clay		63	159	96
Soft zone (no water)		159	161	2
Soft brown clay		161	199	38
Brown sandy clay	X	199	294	95
Soft zone (sand, gravel)	X	294	296	2
Brown clay		296	315	19
Gray sandy clay		315	327	12
Soft zone	X	327	330	3
Gray sandy clay		330	337	7
Soft zone	X	337	341	4
Gray sandy clay		341	350	9

8. WELL CONSTRUCTION  
 Depth Drilled 350 Feet Depth Cased 350 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 50 Feet  
8 5/8 Inches 50 Feet 350 Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>0</u>	<u>350</u>

Perforations:  
 Type perforation Factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 305 feet to 345 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 350 feet

9. WATER LEVEL w/ingrid  
 Static water level: 265 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 15 P.S.I.  
 Water temperature cold °F Quality clear

Date started 4-15-96, 19\_\_\_\_  
 Date completed 4-17-96, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>15</u>		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board: 22549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 923

Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date April 18, 1996