WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51922
Permit No.
Basin 087

NOTICE OF INTENT NO. 32596

1. OWNER LARRY TURK
MAILING ADDRESS 5859 Mt. Rose Hwy
Reno, Nevada 89511

ADDRESS AT WELL LOCATION
same

2. LOCATION NW ¼ SW ¼ Sec. 25 T. 18N N/S R. 19E E. Washoe County
PERMIT NO. (Issued by Water Resources) 049-051-66 (Parcel No.) Mt. Rose Hwy (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulder & clay		0	3	3
Brown clay		3	7	4
Clay & boulders		7	16	9
Boulders		16	18	2
Brown clay w/smaller boulders		18	34	16
Boulder		34	36	2
Brown clay w/volcanic & granite boulders		36	95	59
Granite boulder		95	99	4
Brown clay w/volcanic & granite boulders		99	135	36
Soft zone (granite sands) X		135	155	20
Brown clay some gravel		155	160	5

Date started 4-15-96, 19
Date completed 4-16-96, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
18+		

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	50 Feet	
8 5/8 Inches	50 Feet	160 Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	160

Perforations:
Type perforation Factory sawed slot
Size perforation 3/32 x 3 x 5 around
From feet to feet
From 115 feet to 155 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 95 feet below land surface
Artesian flow G.P.M. 18+ P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 22549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed (By driller performing actual drilling on site or contractor)
Date April 18, 1996

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627