

OFFICE USE ONLY  
 Log No. 51927  
 Permit No. \_\_\_\_\_  
 Basin. 084

I

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31573

1. OWNER Harold & Cathi Ward ADDRESS AT WELL LOCATION Wrangler Road  
 MAILING ADDRESS P.O. Box 51745 Palimino Valley  
Sparks Nevada 89436

2. LOCATION NE 1/4 SW 1/4 Sec 20 T. 22 S. R. 22 East Washoe County  
 PERMIT NO. 077-400-15 Palimino Valley Subdivision Name  
Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
D.G. brown		0	15	
Red andisite		15	65	
Gray clay		65	80	
Red andisite		80	210	
Multi colored volcanic rock		210	310	
Clear quartz		310	345	
Multi colored basalt		345	395	
Multi colored volcanic rock		395	445	
Gray silica sand		445	500	
Multi colored Quartz		500	545	
Orange & clear granite		545	560	
Multi colored granite		560	635	
Red & green volcanic gravels		635	650	
Multi colored gravels & red clay		650	670	
Orange & clear granite		670	740	
Salt & Pepper granite		740	760	
Red & green fractured volcanic rock		760	800	
T.D. 800				
Poured approx 33,075 cement grout to abandon well				

8. WELL CONSTRUCTION  
 Depth Drilled 800 Feet Depth Cased 0 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0	50
8 1/2 Inches	50	378
7 5/8 Inches	378	800

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_

From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started April 29 1996  
 Date completed May 10 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
WELL BORE DRY ABANDON			

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service Inc.  
 Address 1800 1/2 Frazer Avenue  
Sparks Nevada 89431

Nevada contractor's license number issued by the State Contractor's Board 35387-A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509T-1

Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date May 14, 1996