

OFFICE USE ONLY
 Log No. 51932
 Permit No. _____
 Basin. _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31569
5700 Peak Road
Reno Nevada 89510

1. OWNER Lauri & Jerry Jorgenson ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 5700 PEAK Road _____
Reno Nevada 89510 _____

2. LOCATION SE 1/4 NW 1/4 Sec 1 T 22 S R 20 E AST Washoe County _____
 PERMIT NO. 76-241-06 Parcel No. _____ Subdivision Name Palimino Valley Unit 5 1-2-01

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
overburden		0	7	
granite boulder		7	10	
brown DG (soft)		10	20	
black & white granite (fractured)		20	70	
black & white granite (hard)		70	240	
black & white granite hard fractured zone		240	244	
black & white granite med hard		244	315	
fractured blk & white granite w/trace				
black basalt r x		315	345	
black & white granite		345	415	
black & white granite w/trace white clay		415	435	
black & white granite & green clay		435	460	
black & white granite (med hard)		460	475	
T.D.		475		

5000' log # 76089 for PTA

8. WELL CONSTRUCTION
 Depth Drilled 475 Feet Depth Cased 475 Feet

HOLE DIAMETER (BIT SIZE)

From	To
10 5/8 Inches	0 Feet
8 1/2 Inches	52 Feet
6 1/8 Inches	345 Feet
	475 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.92	.188	+2	345
5	6.56	.188	335	475

Perforations:
 Type perforation factory sawed
 Size perforation 1/8 x 3 3/32 x 3
 From 305 feet to 325 feet
 From 455 feet to 475 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 52

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 52 feet to 345 feet

9. WATER LEVEL
 Static water level 140 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started April 15, 1996
 Date completed April 26, 1996

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		8 hours

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. Pump and Well Service Inc. Contractor
 Address 1800 1/2 Frazer Avenue Contractor
Reno Nevada 89431
 Nevada contractor's license number issued by the State Contractor's Board 35387-A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date May 9, 1996