



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 325

1. OWNER MARTIN ANGLIN ADDRESS AT WELL LOCATION: \_\_\_\_\_  
 MAILING ADDRESS P.O. Box 60457 1270 Antelope Valley Road  
Reno, Nevada 89506-0457 Reno, Nevada 89506

2. LOCATION SE 1/4 SW 1/4 Sec. 28 T. 22N N/S R. 19 E. Washoe County Washoe  
 PERMIT NO. 079-410-11 Antelope Valley Park Est. # 176  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock

5. WELL TYPE  Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	3	3
Brown sandy clay		3	26	23
Green sandy clay		26	51	25
Brown sandy clay		51	156	105
Fine brown sand		156	166	10
Brown sandy clay		166	283	117
Brown granite sands with brown clay streaks		283	365	82
Soft sands	X	365	394	29

8. WELL CONSTRUCTION  
 Depth Drilled 394 Feet Depth Cased 394 Feet

HOLE DIAMETER (BIT SIZE)

From	To
10 Inches	0 Feet 50 Feet
8 5/8 Inches	50 Feet 394 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	394

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 329 feet to 389 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 50 feet  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 394 feet

9. WATER LEVEL  
 Static water level 330 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 21 P.S.I.  
 Water temperature cold °F Quality clear

Date started 4-29-96, 19\_\_\_\_\_  
 Date completed 5-2-96, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>21</u>		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NEVADA 89510  
 Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date May 9, 1996