WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51941
Permit No.
Basin C-12A

NOTICE OF INTENT NO. 3628

1. OWNER DON CONYERS
MAILING ADDRESS 5625 Meacham
Carson City, Nevada 89704

ADDRESS AT WELL LOCATION
8205 Osage Road
Reno, Nevada 89506

2. LOCATION SW ¼ SW ¼ Sec. 25 T 21N N/S R 18 E Washoe County
PERMIT NO. (Issued by Water Resources) 086-360-20 (Parcel No.) Silver Knolls (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay		1	62	61
Gray clay		62	76	14
Green clay		76	92	16
Blue clay		92	105	13
Soft zone(gray sand)	X	105	110	5
Blue clay		110	124	14
Brown clay		124	131	7
Soft zone(brown sand)	X	131	140	9
Brown clay		140	141	1
Soft zone(green sand fine to med)	X	141	148	7
Clay		148	149	1

Date started May 6-96, 19
Date completed May 7-96, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30+		

8. WELL CONSTRUCTION
Depth Drilled 149 Feet Depth Cased 149 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	50 Feet
8 5/8 Inches	50 Feet	149 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	149

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 103 feet to 143 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 149 feet

9. WATER LEVEL
Static water level 58 feet below land surface
Artesian flow G.P.M. 30+ P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed [signature] (By driller performing actual drilling on site or contractor)
Date May 9, 1996

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627