



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26472

1. OWNER JOHN & JOANNE MASKER ADDRESS AT WELL LOCATION 115 Alpha Butte
 MAILING ADDRESS 1001 Miramontes Pl. Rd. 115 Alpha Butte
Half Moon Bay, CA 94019 Reno, NV 89506
 2. LOCATION SW 1/4 SE 1/4 Sec. 19 T. 22N N/S R. 19 E Washoe County
 PERMIT NO. 079-352-02 Red Rock Estates #52
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Brown sandy clay		1	18	17
Soft zone(sand)		18	19	1
Brown sandy clay		19	91	72
Soft zone(sand & small gravel)		91	93	2
Brown sandy clay		93	159	66
Soft zone(sand)		159	161	2
Brown sandy clay		161	248	87
Soft zone		248	252	4
Brown sandy clay		252	299	47
Gray sandy clay		299	305	6
Soft zone(app. 3 GPM)	X	305	307	2
Gray sandy clay		307	315	8
Soft zone (sandy & gravels w/clay streaks)	X	315	362	47
Gray sandy clay		362	375	13

8. WELL CONSTRUCTION
 Depth Drilled 375 Feet Depth Cased 375 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 375 Feet
 _____Inches_____Feet_____Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	375

 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 320 feet to 370 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 375 feet

Date started 5-8-96 19_____
 Date completed 5-9-96 19_____

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
25			

9. WATER LEVEL
 Static water level 220 feet below land surface
 Artesian flow _____ G.P.M. 25 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. Box 12370 Contractor
Reno, Nevada 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed Wayne Helman
 By driller performing actual drilling on site or contractor
 Date May 10, 1996