


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY

Log No. 51947  
 Permit No. \_\_\_\_\_  
 Basin 0877



NOTICE OF INTENT NO. 31948

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

OWNER Dave Post

MAILING ADDRESS 700 College Dr.  
Incline Village, NV 89451

ADDRESS AT WELL LOCATION No ADDRESS ASSIGNED YET  
Timberline Dr.

2. LOCATION SE 1/4 NW 1/4 Sec. 34 T 18N N/S R 19E E Washoe County  
 PERMIT NO. Wa Co.5611 049-060-23

Issued by Water Resources

Parcel No.

Subdivision Name

3. WORK PERFORMED

- New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE

- Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE

- Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Drilled to 210' and cased with 6".</u>				
<u>Drilled to 400' and cased with 5".</u>				
<u>Fracture 135, 170'- 5-8 gpm. Most water 340-400'.</u>				
<u>Top soil &amp; brown clay</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Boulders/w brown &amp; tank clay</u>		<u>3</u>	<u>20</u>	<u>17</u>
<u>Red &amp; Black volcanics</u>		<u>20</u>	<u>70</u>	<u>50</u>
<u>Brown clay w/ volcanics</u>		<u>70</u>	<u>85</u>	<u>15</u>
<u>See next line</u>	<u>x</u>	<u>85</u>	<u>340</u>	<u>255</u>
<u>Red &amp; black volcanics w/quartz</u>				
<u>See next line</u>	<u>xx</u>	<u>340</u>	<u>400</u>	<u>60</u>
<u>Red &amp; black volcanics w/ brn rock</u>				

8. WELL CONSTRUCTION

Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

	From	To	
<u>9 7/8"</u>	<u>0</u>	<u>210</u>	<u>Feet</u>
<u>6 1/8"</u>	<u>210</u>	<u>400</u>	<u>Feet</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.93</u>	<u>.188</u>	<u>+1</u>	<u>210</u>
<u>5"</u>	<u>10.79</u>	<u>.188</u>	<u>200</u>	<u>400</u>

Perforations:

Type perforation Factory  
 Size perforation 3/32 x 3" single row  
 From 190 feet to 210 feet  
 From 360 feet to 400 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 100  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 100 feet to 200 feet

9. WATER LEVEL

Static water level 150 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality Not tested

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Bruce MacKay Pump & Well Service, Inc.  
 Contractor  
 Address 1600 Mt. Rose Hwy  
 Contractor  
RENO, NV 89511  
 Nevada contractor's license number issued by the State Contractor's Board 23096  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719  
 Signed R. Bruce MacKay  
 By driller performing actual drilling on-site or contractor  
 Date 5-21-96

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>		<u>1 hr.</u>

Date started 5/13/96 19\_\_\_\_  
 Date completed 5/17/96 19\_\_\_\_