

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30402

1. OWNER Clark Builders ADDRESS AT WELL LOCATION 1915 Mackenzie Ct. James Monroe Ave
 MAILING ADDRESS 2175 Clark Blvd Battle Mountain, NV 89820

2. LOCATION SW 1/4 SW 1/4 Sec. 34 T. 32 S. R. 45 E. Lander County
 PERMIT NO. D-2 Parcel No. Clark Parcels Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	4	4
Fine Sand & Gravel		4	30	26
Brown Clay		30	43	13
Layered Sand & Clay	X	43	55	12
Blue Grey Clay		55	78	23
Sand	X	78	95	17
Blue Sandy Clay		95	100	5
Sand & Fine Gravel	X	100	120	20

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10-5/8 Inches 0 Feet 120 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13	.188	+1-1/2	120

Perforations:
 Type perforation Millslot
 Size perforation 3/16" x 3"
 From 100 feet to 120 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Depth of Seal 50 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 50 feet to 120 feet

9. WATER LEVEL
 Static water level 18 feet below land surface
 Artesian flow -- G.P.M. -- P.S.I.
 Water temperature Cold °F Quality --

Date started January 18, 19 96
 Date completed January 19, 19 96

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Blow Test	25		9 Hours

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hackworth Drilling, Inc. Contractor
 Address P.O. Box 850 Contractor
Elko, NV 89803

Nevada contractor's license number 020582
 issued by the State Contractor's Board

Nevada driller's license number issued by the
 Division of Water Resources, the on-site driller: 1654

Signed John C. Biv
 By driller performing actual drilling on site or contractor
 Date 2-6-96