

OFFICE USE ONLY
 Log No. 51972
 Permit No. _____
 Basin 177

I

NOTICE OF INTENT NO. 330

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

1. OWNER Gary Sprouse ADDRESS AT WELL LOCATION 3 miles south of Ely
 MAILING ADDRESS HC 66 Box 56A
Neola, Utah 84053

2. LOCATION SE 1/4 SE 1/4 Sec 35 T. 16 N. 63 E. White Pine County
 PERMIT NO. Well No 6 11C Blue Diamond Country Estates
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel		0	20	20
Clay & Gravel		20	35	15
Cemented Gravel		35	170	135
Clay/ Sand & Gravel		170	265	95
Clay		265	275	10
Water Sand & Gravel/	x	275		
Clay Seams			320	45
Clay & Gravel		320	355	35
Water Sand & Gravel/	x	355		
Clay Seams			365	10
Clay & Gravel		365	380	15
Water Sand & Gravel/	x	380		
Clay Seams			385	5
Clay & Gravel		385	400	15
Water Sand & Gravel/	x	400		
Clay Seams			407	7

8. WELL CONSTRUCTION
 Depth Drilled 407 Feet Depth Cased 407 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 407 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	407

Perforations:
 Type perforation Factory
 Size perforation 1/8" x 2 1/2" 6 rows
 From 267 feet to 407 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 ft Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 407 feet

9. WATER LEVEL
 Static water level 289 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

Date started May 13, 19 96
 Date completed May 20, 19 96

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	111	1 1/2

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Christiansen Drilling, Inc Contractor
 Address 557 Ely Avenue Contractor
Ely, NV 89301

Nevada contractor's license number issued by the State Contractor's Board 14790
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641

Signed Jarold D. Christiansen
 By driller performing actual drilling on site or contractor
 Date June 5, 1996