

OFFICE USE ONLY
 Log No. 51974
 Permit No. _____
 Basin _____

I

NOTICE OF INTENT NO. 22875

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER S&H INVESTMENTS/HUGH HUTCHINS ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1055 West Moana Ln. Suite #4 460 Anitra Dr. Reno, Nevada 89511
RENO, NEVADA 89509

2. LOCATION SE 1/4 NW 1/4 Sec 2 T 18N N/S R 19E E Washoe County _____
 PERMIT NO. R-282 041-110-65 Anitra Subdivision
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Black clay w/boulders		0	2	2
Gray volcanic rock		2	14	12
Brown volcanic rock		14	29	15
Red/brown "		29	34	5
Tan/brown "		34	87	53
Redish brown "		87	90	3
" " w/soft & hard streaks		90	163	73
Dark gray volcanic rock broken & fractured		163	171	8
Dark gray volcanic rock/harder		171	176	5
" " w/clay streaks		176	200	24
Gray soft volcanic rock		200	225	25
" " w/clay streaks		225	251	26
Tan clay/weathered rock streaks		251	288	63
Orange/tan soft rock		288	292	4
Bright red volcanic rock (Iron odor)		292	330	38
Tan rock		330	340	10
Tan rock Iron odor		340	365	25
" " softer		365	390	35
Redish tan volcanic rock		390	395	5
Gray rock w/fractures		395	409	14
Tan rock		409	430	21
Yellow weathered rock	X	430	433	3
Mustard yellow rock		433	435	2
Brown volcanic rock		435	455	20
Tan/brown " " caving	X	455	460	5

8. WELL CONSTRUCTION
 Depth Drilled 460 Feet Depth Cased 0 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 460 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
NOTE: Test hole has 3' of 10" starter pipe in hole with cap to secure site.				

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started 3-29-96, 19_____
 Date completed 3-30-96, 19_____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NOTE: This hole was caving faster than we could clear cuttings. Also seemed to have a lot of minerals in water. Decided to try a 2nd site & abandoned this site.		

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality High in Iron

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING INC.
Contractor

Address P.O. BOX 12370
Contractor
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908

Signed [Signature]
 By _____ performing actual drilling on site or contractor
 Date April 25, 1996