WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51979
Permit No.
Basin 7

NOTICE OF INTENT NO. 32727

1. OWNER Western Energetix
MAILING ADDRESS 5690 Riggins Ct. Ste. A Reno Nv 89502
ADDRESS AT WELL LOCATION 1250 W. 4th St Reno Nv.

2. LOCATION SE ¼ NE ¼ Sec. 10 T. 19 N R. 19 E Washoe County
PERMIT NO. MOGGS 665A (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic SVW ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other ?

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| pressure grout 3/4" to gs | | to 50+ psi | | |
| Try to pull 3/4" out of 4" | | | | |
| NO GO - BROKEN BGS | | | | |
| TRY TO pull 4" | | | | |
| Broken BGS | | | | |
| Fill to GS w/ neatcement | | | | |
| 3/4" pipe sealed inside | | | | |
| 4" for sparge | | | | |
| sparge | | | | |
| SVW-2 | | Vacuum Water Recovery | | |

Date started 5.9.96, 19
Date completed 5.9.96, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled ? Feet Depth Cased 37.4 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| ? Inches | Feet | Feet |
| ? Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4" | | SCH 80 | 0 | 30 |
| 3/4" | | " " | 0 | 36 |

Perforations:
Type perforation SLOT/DIFUSER
Size perforation
From feet to feet
From 30 feet to 37.4 feet 4"
From feet to feet
From 36 feet to 37.4 feet 3/4"

Surface Seal: ☑ Yes ☐ No
Depth of Seal 37.4
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 17.25 Aux. feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nevada Drilling Inc (Contractor)
Address 75 Lewers Creek Rd Carson City NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 13697A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1902
Signed John B. Leiant (By driller performing actual drilling on site or contractor)
Date 5-23-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627