

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24733

1. OWNER GRANITE CONST. CO. ADDRESS AT WELL LOCATION N HWY 395 GARDNERVILLE
 MAILING ADDRESS 5855 SHEEP RD CARSON CITY, NV

2. LOCATION NE 1/4 NE 1/4 Sec 23 T. 12 N S R. 20 E DOUGLAS County
 PERMIT NO. 29-030-03 RUHENSTROTH Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MVD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy clay 1/2 cobbles-gravel		0	20	20
Cobbles-gravel some s.l.		20	90	70
Sandy clay 1/2 cobbles-gravel		90	96	6
Cobbles-gravel 1/2 some s.l.		96	158	62
Sandy clay 1/2 gravel		158	167	9
gravel 1/2 some s.l.	/	167	205	38
Sandy clay some gravel		205	210	5
gravel 1/2 some s.l.	/	210	217	7
Sandy clay 1/2 some s.l.		217	222	5
gravel 1/2 short s.l. str.	//	222	260	38

8. WELL CONSTRUCTION
 Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0	100 Feet
9 7/8 Inches	100	260 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	260

Perforations:
 Type perforation FACTORY SLOTTED/T.C.
 Size perforation 1/2 x 3
 From T.C. 220 feet to 240 feet
 From Factory 240 feet to 260 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 100

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From 100 feet to 260 feet

9. WATER LEVEL
 Static water level 102 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD FALLON, NV 89406 Contractor
 Nevada contractor's license number issued by the State Contractor's Board: 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1535
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 3-21-96

Date started 3-12 1996
 Date completed 3-21 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>AIR</u>	<u>15+</u>	<u>—</u>	<u>3</u>

RECEIVED
 26 MAR 25 PM 12:11
 STATE ENGINEERS OFFICE