WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51986
Permit No.
Basin 185

NOTICE OF INTENT NO. 24737

1. OWNER J + D CONSTRUCTION
MAILING ADDRESS MINDEN, NV
ADDRESS AT WELL LOCATION 1606 DOWNS MINDEN

2. LOCATION SW ¼ NW ¼ Sec. 35 T 14 (N)S R 20 E DOUGLAS County
PERMIT NO. — (Issued by Water Resources) 21-260-06 (Parcel No.) JOHNSON LANE (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand w/large gravel		0	10	10
gravel w/sandy clay		10	30	20
Sandy clay		30	37	7
gravel w/sandy clay		37	47	10
Sandy clay		47	58	11
small gravel w/sandy clay		58	90	32
sandy clay w/some gravel		90	98	8
gravel w/sandy clay		98	118	20
gravel w/short clay sticks		118	155	37
Small gravel w/some clay	//	155	192	37
Sandy clay w/course sand		192	200	8

Date started 2-16, 1996
Date completed 2-27, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	15+	—	

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	50 Feet
9 7/8 Inches		50 Feet	200 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12	.188	+2	200

Perforations:
Type perforation FACTORY SLOTTED/T.C.
Size perforation 1/8 x 3
From T.C. 180 feet to 200 feet
From Factory 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 119 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDCO EXPLORATION, INC (Contractor)
Address 7780 CURRY RD (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed Gerald W. Kimmell (By driller performing actual drilling on site or contractor)
Date 2-27-96

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627