WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51991
Permit No.
Basin 100

NOTICE OF INTENT NO. 31564

1. OWNER Keith Everett
MAILING ADDRESS 17760 Aspen Drive
Reno, Nevada 89506

ADDRESS AT WELL LOCATION 17760 Aspen Drive
Reno, Nevada 89506

2. LOCATION NE ¼ NW ¼ Sec. 20 T. 21N N/S R. 18 East Washoe County
PERMIT NO. Issued by Water Resources | 87-044-19 Parcel No. | Northridge Small Estates Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [XX] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [XX] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburdened		0	6	
Gray Clay		6	60	
Gray Clay & Sand				
Multi Colored Course		60	110	
Multi Colored				
Gravels		110	140	
T.D. 140'				

Date started March 25, 19 96
Date completed March 27, 19 96

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		2 hours

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10-5/8 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13.92	-188	1-1/2	140

Perforations:
Type perforation Factory Sawed
Size perforation 3/32X3
From 140 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [XX] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 140' feet to 100' feet

9. WATER LEVEL
Static water level 6' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A.S.A.P. Pump & Well Service, Inc. (Contractor)
Address 1800 1/2 Frazer Avenue (Contractor)
Sparks, Nevada 89431
Nevada contractor's license number issued by the State Contractor's Board 35387-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509-T1
Signed Larry Welch (By driller performing actual drilling on site or contractor)
Date March 28, 1996

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627