

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE-USE-ONLY  
 Log No. 51993  
 Permit No. 105  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28120

1. OWNER Angelo Pecorilla ADDRESS AT WELL LOCATION 1864 Pinenut Rd  
 MAILING ADDRESS 1864 Pinenut Rd Gardnerville NV, 89410  
 2. LOCATION SW 1/4 SW 1/4 Sec 12 T 12 S R 20 E Douglas County  
 PERMIT NO. 23-223-09 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Drilled out steel and Debris that was in Bottom of old well		175	180	5
course Sands and small Gravels	xxx	180	215	35

8. WELL CONSTRUCTION  
 Depth Drilled 215 Feet Depth Cased 175-215 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 6 1/8 Inches 180 Feet 215 Feet  
 To \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>5 9/16</u>	<u>10.87</u>	<u>.184</u>	<u>175</u>	<u>215</u>

Perforations:  
 Type perforation N.I. Slot  
 Size perforation 3x 3/32  
 From 175 feet to 215 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal N/A  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From N/A feet to N/A feet

9. WATER LEVEL  
 Static water level 85 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 20-25 P.S.I.  
 Water temperature Cold °F Quality Good

Date started 3-23 1996  
 Date completed 3-24 1996

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>25</u>	<u>65</u>	<u>3 HRS</u>	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A. H. Pump Co. Contractor  
 Address 5551 Hwy 50 E #3 Contractor  
Coron City NV. 89701  
 Nevada contractor's license number 31839  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the 1905  
 Division of Water Resources, the on-site driller.  
 Signed Richard L. Clark  
 By driller performing actual drilling on site or contractor  
 Date 3-27-96