WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51994
Permit No.
Basin 044

NOTICE OF INTENT NO. 30395

1. OWNER Tom Stafford
MAILING ADDRESS 160-15 Kittridge Canyon
Elko, NV 89801

ADDRESS AT WELL LOCATION N. Side of 4th St.
between Truckee River Blvd & White Blvd

2. LOCATION NE ¼ NW ¼ Sec. 27 T. 36 N/S R. 57 E. Elko County
PERMIT NO. (Issued by Water Resources) 24-042-12-9 (Parcel No.) River Valley Ranch #1 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Topsoil		0	3	3'
Sand & Pea Gravel	X	3	45	42'
Clay		45	51	6'
Sand & Fine Gravel	X	51	80	29'
Clay		80	86	6'
Coarse Gravel & Sand	X	86	110	24'

Date started 3-21, 1996
Date completed 3-25, 1996

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Blow Test	40		3-1/2

8. WELL CONSTRUCTION
Depth Drilled 110 Feet Depth Cased 110 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10-5/8 Inches	0 Feet	50 Feet
9-7/8 Inches	50 Feet	110 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13	.188	+1-1/2	110

Perforations:
Type perforation Millslot
Size perforation 3/16 x 3"
From 90 feet to 110 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [X] Poured

Seal Type:
[X] Neat Cement
[ ] Cement Grout
[X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 110 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow ----- G.P.M. ----- P.S.I.
Water temperature Cold °F Quality -----

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hackworrth Drilling Inc. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 3-26-96

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627