

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 2727

1. OWNER Western Energetix ADDRESS AT WELL LOCATION 1250 W. 4th St
 MAILING ADDRESS 5690 RIGGINS CT STE A RENO NV 89502
 2. LOCATION SE 1/4 NE 1/4 Sec 10 T. 19 N. R. 19 E Washoe County
 PERMIT NO. MD 665 665A Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic S/V Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other 3

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>BOTTOM</u>				
<u>BREAK END OF PIPE OFF</u>				
<u>TRY TO PULL PUL</u>				
<u>BROKEN GAS</u>				
<u>RUN TRENCH</u>				
<u>PUMP CEMENT TO GS</u>				
<u>Pressure grout the 3/4" pipe from SURFACE to 50 + psi</u>				
<u>3/4" pipe sealed in ground next to, on outside of 4" pipe</u>				
<u>SV-1 (SPARG-VACUUM)</u>				

8. WELL CONSTRUCTION
 Depth Drilled ? Feet Depth Cased 29.2 Feet 4"
43.6 Feet 3/4"
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>		<u>sch 80</u>	<u>0</u>	<u>5</u>
<u>3/4"</u>		<u>sch 80</u>	<u>0</u>	<u>42</u>

Perforations:
 Type perforation _____
 Size perforation SLOT
 From _____ feet to _____ feet
 From 5 feet to 29.2 feet 4"
 From _____ feet to _____ feet
 From 42 feet to 43.6 feet 3/4"
 Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 29.2 + 43.6 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 17-25 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 5.9. 1996
 Date completed 5.9 1996

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name NEVADA DRILLING INC
 Address 75 Jewers creek rd
CARSON CITY NV
 Nevada contractor's license number 13697A
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1902
 Signed John B. Seibel
 Date 5.23.96