

OFFICE USE ONLY
 Log No. 52051
 Permit No. 105
 Basin

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24721

1. OWNER NV DIV OF FORESTRY ADDRESS AT WELL LOCATION JACKS VALLEY RD
 MAILING ADDRESS CARSON CITY, NV MINDEN NV

2. LOCATION SW 1/4 SE 1/4 Sec. 11 T 14 N R 19 E DOUGLAS County
 PERMIT NO. 54589 Issued by Water Resources Parcel No. 15-093-05 Subdivision Name JACKS VALLEY

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MVD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>DG 1/2 sandy clay</u>		<u>0</u>	<u>12</u>	<u>12</u>
<u>DG</u>		<u>12</u>	<u>42</u>	<u>30</u>
<u>DG 1/2 sandy clay</u>		<u>42</u>	<u>138</u>	<u>96</u>
<u>DG 1/2 short clay streaks</u>	<input checked="" type="checkbox"/>	<u>138</u>	<u>181</u>	<u>43</u>
<u>Fractured Granite</u>	<input checked="" type="checkbox"/>	<u>181</u>	<u>187</u>	<u>6</u>

8. WELL CONSTRUCTION
 Depth Drilled 187 Feet Depth Cased 187 Feet

HOLE DIAMETER (BIT SIZE)
 From To
12 3/4 Inches 0 Feet 187 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>17</u>	<u>.188</u>	<u>+2</u>	<u>187</u>

Perforations:
 Type perforation Factory Slotted / T.C.
 Size perforation
 From T.C. 140 feet to 760 167 feet
 From Factory 167 feet to 187 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 100'
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 100' feet to 187 feet

Date started 1-2, 1996
 Date completed 1-10, 1996

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>15+</u>	<u>—</u>	<u>4</u>

9. WATER LEVEL
 Static water level 88 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD Contractor
FALLON, NV 89406
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
 Signed Jerald W. Shimmell
 By driller performing actual drilling on site or contractor
 Date 1-16-96