

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31875

1. OWNER Greg Chapin
 MAILING ADDRESS 5360 Madeiros
Sun Valley, NV 89433
 ADDRESS AT WELL LOCATION 1230 Bullion Hill Rd
Reno, NV 89506
 2. LOCATION SE 1/4 SW 1/4 Sec 17 T. 22N
N/S R 19 East Washoe County
 PERMIT NO. 079-400-01
 Issued by Water Resources Parcel No. Subdivision Name Red Rock Estates #119

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	6	
Brown D.G.		6	17	
Blk & White Granite				
Soft		17	60	
Blk & White Granite				
w/Green Volcanic Rock		60	330	
Blk & White Granite				
w/Green Volcanic Rock				
Trace Green Clay				
(Fractured)		330	370	
Blk & White Granite				
Some Green Volcanic				
Rock Trace Green Clay		370	395	
Blk & White Granite				
Multipal Fractures				
(Med. Hard)		395	495	
Blk & White Granite				
Med Hard		495	520	
Blk & White Granite				
Hard Fractured		520	530	
Blk & White Granite				
(Hard)		530	575	

8. WELL CONSTRUCTION
 Depth Drilled 575 Feet Depth Cased 575 Feet
 HOLE DIAMETER (BIT SIZE)

	From	To
10-5/8 Inches	0	51 Feet
8-1/2 Inches	51	495 Feet
6-1/8 Inches	495	575 Feet

 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13.92	.188	+1-1/2	495
5	13.92	.188	475	575

 Perforations:
 Type perforation Factory Sawn
 Size perforation 3/32 X 3
 From 455 feet to 475 feet
 From 595 feet to 575 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 51
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 51 feet to 495 feet

T.D. 575
 Date started December 20, 1995
 Date completed January 3, 1996

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
5		3 hours

9. WATER LEVEL
 Static water level 125 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. Pump & Well Service, Inc.
 Contractor
 Address 1800 1/2 Frazer Ave.
 Contractor
Sparks, Nevada 89431
 Nevada contractor's license number 35387-A
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1509
 Division of Water Resources, the on-site driller
 Signed Randy Welch
 By driller performing actual drilling on site or contractor
 Date February 2, 1996