

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32528

1. OWNER LARRY GILBERT ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 399 Oregon Blvd.
Reno, Nevada 89506
 2. LOCATION NW 1/4 NW 1/4 Sec 15 T 21N N/S R 19 E Washoe County
 PERMIT NO. 080-357-01 Lemmon Valley Subdivision Name
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Bottom of well at 480 ft.				
Static water level at 323 ft.				
GPM 2				
WELL DEEPENING				
Gray granite with clay streaks		480	499	19
Gray granite		499	510	11
Weathered granite soft, clay streaks		510	542	32
Fracture	X	542	543	1
Gray granite		543	563	20
Fracture granite	X	563	570	7
Gray granite		570	575	5
Bottom of hole very unstable, cave in last 5'				

8. WELL CONSTRUCTION
 Depth Drilled 575 Feet Depth Cased 570 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
6 1/8 Inches 480 Feet 575 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5" OD		.188	0	570

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 490 feet to 510 feet
 From 525 feet to 565 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal deepening Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 480 feet to 570 feet

Date started 6-10-96, 19____
 Date completed 6-12-96, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
14		

9. WATER LEVEL
 Static water level 283 feet below land surface
 Artesian flow _____ G.P.M. 14 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date June 14, 1996