

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER UNR ADDRESS AT WELL LOCATION 4125 Mt. Lora St Reno, NV
MAILING ADDRESS _____ (STead) #28
2. LOCATION NE 1/4 SW 1/4 Sec. 29 T 21 R 19 E Washoe County
PERMIT NO. MO 955-A Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic SBVW Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
ASPHALT		0"	6"	
BROWN CLAYEY FINE TO MEO. SANDS		6"	8'	
Reddish Brown cemented silty fine sands		8'	12'	
BROWN SANDY CLAY		12'	15'	
Grey poorly graded med. sands		15'	23'	
BROWN VERY FINE TO MEO. SANDS		23'	30'	
GREY FINE TO MEO. POORLY GRADED SANDS		30'	38'	

8. WELL CONSTRUCTION
Depth Drilled 38 Feet Depth Cascd 1027 2038' Feet
HOLE DIAMETER (BIT SIZE)
From 10 Inches To 38 Feet
Inches. Feet. Feet.
Inches. Feet. Feet.

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
#1 1.32		SCH 80	0	17
#2 1.32	1" ID	SCH 80	0	36.5
#3 1.9"	1/2" ID	SCH 80	0	36

Perforations:
Type perforation SLOT/ceramic diffuser #2
Size perforation .020"
#1 From 17 feet to 27 feet 2" ID
#2 From 36.5 feet to 38 feet ceramic
#3 From 36 feet to 38 feet 2" ID

Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal 13 Cement Grout
Placement Method: Pumped Poured Concrete Grout
Gravel Packed: Yes No peephla Bent. Pellets @ 30'-34'
From 13 / 34 feet to 30 / 38 feet

9. WATER LEVEL
Static water level 26 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nevada Drilling Inc Contractor
Address 75 Jewers creek RD Contractor
CARSON CITY NV 89704
Nevada contractor's license number 13697A issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1902
Signed John B. Seibel
By driller performing actual drilling on site or contractor
Date 6.11.96

Date started 4.19, 1996
Date completed 4.19, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			