WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 52094, 52095, 52096
Permit No.
Basin 092AT

NOTICE OF INTENT NO. 28144

1. OWNER UNR
MAILING ADDRESS

ADDRESS AT WELL LOCATION 14125 Mt. Lola St Reno, NV (Stead) #28

2. LOCATION NE ¼ SW ¼ Sec. 29 T. 21 N/S R. 19 E. Washoe County
PERMIT NO. MO 955-A
Issued by Water Resources | Parcel No. | Subdivision Name

SOIL BIO VENT WELL

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic SBVW ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT		0"	6"	
BROWN CLAYEY FINE TO MED. SANDS		6"	8'	
REDDISH BROWN CEMENTED SILTY FINE SANDS		8'	12'	
BROWN SANDY CLAY		12'	15'	
				#1
GREY poorly graded med. SANDS		15'	23'	#2
				#3
BROWN VERY FINE TO MED. SANDS.		23'	30'	
				#1
GREY FINE TO MED. POORLY GRADED SANDS		30'	38'	#2
				#3
BLDG #28				
SBV #5				

Date started 4.19, 1996
Date completed 4.19, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 38 Feet Depth Cased 1@27 2@38' Feet

HOLE DIAMETER (BIT SIZE)
10 Inches From 0 Feet To 38 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
1.32		SCH 80	0	17
1.32	1." ID	SCH 80	0	36.5
.9"	1/2" ID	SCH 80	0	36

Perforations:
Type perforation SLOT / ceramic diffuser #2
Size perforation .020
From 17 feet to 27 feet 2" ID
From feet to feet
From 36.5 feet to 38 feet ceramic
From 36 feet to 38 feet 2" ID
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 13
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 13 / 34 feet to 30 / 38 feet
#1 #2-3 #1 #2-3
pellplug BENT. PELLETS @ 30'-34'

9. WATER LEVEL
Static water level 26 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nevada Drilling Inc (Contractor)
Address 75 lewers creek RD (Contractor)
Carson City NV 89704
Nevada contractor's license number issued by the State Contractor's Board 13697A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1902
Signed John G. Leised
By driller performing actual drilling on site or contractor
Date 6.11.96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627