WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 52103
Permit No.
Basin C84

NOTICE OF INTENT NO. 33216

1. OWNER Dale & Jessica Morton
MAILING ADDRESS P.O. Box 912
Sparks Nevada 89432

ADDRESS AT WELL LOCATION Lost Springs Road
Reno Nevada 89510

2. LOCATION NE ¼ NE ¼ Sec. 3 T. 22 N/S R. 20 East WASHOE County
PERMIT NO. (Issued by Water Resources) 076-120-10 (Parcel No.) Palimino Valley Unit 3 (Subdivision Name) 3-2-8-2

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [XX] Rotary [ ] RVC
[ ] Air [ ] Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	35	
Brown Course Sand		35	60	
Multi colored Course Sand		60	165	
Multi colored gravel		165	180	
Brown Clay		180	330	
Multi colored course sand		330	386	
T.D. 386'				
See log # 69564 for deepening				

Date started May 15, 1996
Date completed May 22, 1996

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
8		6 hrs.

8. WELL CONSTRUCTION
Depth Drilled 386 Feet Depth Cased 386 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	220 Feet
8 3/4 Inches	220 Feet	386 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.92	-188	-1½	386

Perforations:
Type perforation well screen
Size perforation .030
From 356 feet to 366 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [XX] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 386' feet to 50' feet

9. WATER LEVEL
Static water level 280 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service Inc. (Contractor)
Address 1800½ Frazer Avenue (Contractor)
Sparks Nevada 89431

Nevada contractor's license number issued by the State Contractor's Board 35387-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509T-1

Signed Larry Welch
By driller performing actual drilling on site or contractor
Date May 28, 1996

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627