WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 52297
Permit
Basin 212

NOTICE OF INTENT NO. 17537

1. OWNER REBEL TANK FARM c/o
MAILING ADDRESS Broadbent & Associates
833 Nevada Hwy, #4, Boulder City, NV 89005

ADDRESS AT WELL LOCATION REBEL TANK FARM
5054 N. SLOAN DR.

2. LOCATION NW ¼ SW ¼ Sec 34 T 19 N/S R 62 E/W CLARK County
PERMIT NO. MO-2690 Issued by Water Resources
520-650-004 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE MW-8
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG MW-8

Material	Water Strata	From	To	Thickness
SILTY SAND w/ CLAY		0'	10'	10'
SILTY CLAY w/ GRAVEL		10'	19'	9'
CALICHE		19'	22'	3'
SILT w/ some CLAY		22'	40'	18'
SAND-SILT mix, some gravel		40'	57'	17'
SILTY CLAY w/ SAND		57'	120'	63'

Date started March 12, 1996
Date completed March 12, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	120 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.218	0'	120'

Perforations:
Type perforation Factory Slot
Size perforation 0.020"
From 80 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0'-70' Cement Grout, 70'-74' Bentonite
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 74 feet to 120 feet

9. WATER LEVEL
Static water level ≈100 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name KENT GROOVER
Contractor
Address 731 PILOT RD., STE H
Contractor
LAS VEGAS, NV 89119
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1953
Signed
By driller performing actual drilling on site or contractor
Date 7-8-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627