

OFFICE USE ONLY  
 Log No. 52308  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_  
 NOTICE OF INTENT NO. 1664

**WELL DRILLERS REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Dwight Crossland ADDRESS AT WELL LOCATION in Book  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SW 1/4 NW 1/4 Sec. 20 T. 16 N/S R. 48 E. NYE County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand with sticks off 5/16 gravel 1/16 0</u>		<u>0</u>	<u>125</u>	<u>125</u>
<u>First water</u>	<u>66</u>			
<u>Main water strata</u>	<u>106</u>			

8. WELL CONSTRUCTION  
 Diameter hole 12 1/4 inches Total depth 125 feet  
 Casing record 6 3/8 156  
 Weight per foot \_\_\_\_\_ Thickness 12.6  
 Diameter From To  
6 3/8 inches 0 feet 125 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type Cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 125 feet  
 Perforations:  
 Type perforation Tool 6" x 1/16  
 Size perforation \_\_\_\_\_  
 From 125 feet to 85 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

**RECEIVED**  
 JUL 18 1984  
 Div. of Water Resources  
 Branch Office — Las Vegas, Nev.

9. WATER LEVEL  
 Static water level 60 feet below land surface  
 Flow Good G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature \_\_\_\_\_ ° F. Quality good

Date started 7-9, 1984  
 Date completed 7-11, 1984

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Vegas Drilling Contractor  
 Address 5333 Day Ave Contractor  
 Nevada contractor's license number 015972  
 Nevada contractor's drillers number 944  
 Nevada driller's license number 944 Actual Driller  
 Signed Paul Robinson Contractor  
 Date 7-12-84

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. 60 AIR Draw down 25 feet 3 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours