52309

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 52309
Permit No.
Basin 162

NOTICE OF INTENT NO. 17773

1. OWNER Les Housel
MAILING ADDRESS 1911 W. Jarvis
Pahrump, NV 89041

ADDRESS AT WELL LOCATION 1911 W. Jarvis
Pahrump, NV 89041

2. LOCATION NW ¼ NW ¼ Sec. 29 T. 19S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) | 29-405-07 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GREY CALICHIA		0	23	15
GREY POP CORN CAL.		23	46	18
GREY CLAY	x	46	72	13
BEIGE CLAY	x	72	89	22
BROWN CLAY	x	89	107	14
BROWN CALICHIA	x	107	126	23
DARK BROWN CLAY	x	126	140	22

DCNR/DWR JUL 10 1996 LAS VEGAS OFFICE

Date started June 3, 19 96
Date completed June 4, 19 96

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	NA	½

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches	0 Feet	140 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	140

Perforations:
Type perforation Torch
Size perforation ¼ x 6
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 90 feet to 140 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Larry Jenkins (Contractor)
Address P.O. Box 3392 (Contractor)
Pahrump NV 89041
Nevada contractor's license number issued by the State Contractor's Board 0035901
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1916
Signed Larry Jenkins
By driller performing actual drilling on site or contractor
Date 6-18-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627