+ Pah

DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 52521
Permit No.
Basin 162

1. OWNER James Butman - ADDRESS Pahrump Nevada - at the end of Basin Road - 7

2. LOCATION S.W. ¼, S.E. ¼ Sec. 7 T. 20 S N/S R. 53 E. NYE County
PERMIT NO. Domestic

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Clay streks of Caliche	31	3	36	33
Blue clay w/gravel streks		36	90	54
Sandy clay		90	105	15
Clay streks of gravel		105	160	55

RECEIVED
JUL 30 1971
DIV. OF WATER RESOURCES
BRANCH OFFICE
LAS VEGAS, NEVADA

Date started July 10, 19 71
Date completed July 11, 19 71

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. good Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 3/4 inches Total depth 160 feet
Casing record 8 5/8
Weight per foot 10.75 Thickness 10 gage

Diameter	From	To
8 5/8 inches	0 feet	160 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type Cement
Depth of seal 50 feet - feet
Gravel packed: Yes ☐ No ☐
Gravel packed from 50 feet to 160 feet

Perforations:
Type perforation Torch Cut
Size perforation 1/4" X 8" X 3 Rounds -
From 60 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 30 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ron Floyd Pump & Drilling
Address P.O. Box 157 Pahrump
Nevada contractor's license number 7479
Nevada driller's license number 4761
Signed Penny E. Floyd
Date 7-28-71

USE ADDITIONAL SHEETS IF NECESSARY

5471