


OFFICE USE ONLY  
 Log No. 52641  
 Permit No. \_\_\_\_\_  
 Basin 162



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17774

1. OWNER Richard Varner ADDRESS AT WELL LOCATION 1380 W. Moose Pahrump, NV 89041  
 MAILING ADDRESS 1380 W. Moose Pahrump, NV 89041

2. LOCATION NW 1/4 NE 1/4 Sec 29 T 20S N/S R. 53 E Nye County Nye  
 PERMIT NO. 39-032-22

Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN CALICHIA		0	13	12
GREY CALICHIA		13	34	18
GREY	X	34	62	21
GREY CLAY	x	62	88	15
GREY CLAY	x	88	98	13
GREY POP CORN CAL.	x	98	107	22
GREY CALICHIA	x	107	129	18
BEIGE CLAY	x	129	133	13
BEIGE CLAY	x	133	140	22

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
12 Inches 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	140

Perforations:  
 Type perforation Torch  
 Size perforation 1/4 x 6  
 From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 90 feet to 140 feet

9. WATER LEVEL  
 Static water level 50 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

Date started June 6, 1996.  
 Date completed June 7, 1996.

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	50	NA	1/2

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Larry Jenkins  
 P.O. Box 3392  
 Address \_\_\_\_\_  
 \_\_\_\_\_  
Pahrump NV 89041

Nevada contractor's license number issued by the State Contractor's Board 0035901  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916

Signed Larry Jenkins  
 By driller performing actual drilling on site or contractor  
 Date 6.18.96