

OFFICE USE ONLY  
 Log No. 52644  
 Permit No. \_\_\_\_\_  
 Basin 162



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17787

1. OWNER conrad Menconi ADDRESS AT WELL LOCATION National Road  
 MAILING ADDRESS National rd Pahrump Nv 89041  
 LOCATION NE 1/4 SE 1/4 Sec 31 T 20S N/S R 54 E Nye County  
 PERMIT NO. 41-162-01 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other  
 4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN CLAY		0	18	14
DARK BROWN CLAY		18	37	17
BROWN CLAY		37	48	12
GREY CLAY	x	48	69	18
POPCORN CALICHIA	x	69	84	22
CALICHIA	x	84	99	17
GREY CLAY	x	99	122	16
LIGHT GREY CLAY	x	122	155	18

8. WELL CONSTRUCTION  
 Depth Drilled 155' Feet Depth Cased 155 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
1.2 Inches 0 Feet 155 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	155

Perforations:  
 Type perforation Torch  
 Size perforation 1/2 x 6  
 From 115 feet to 135 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal \_\_\_\_\_  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 105 feet to 155 feet

9. WATER LEVEL  
 Static water level 50 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

Date started June 16, 1996.  
 Date completed june 17, 1996.

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
50	NA	1/2	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Larry Jenkins Contractor  
 Address PO BOX 3392 Contractor  
Pahrump NV 89041  
 Nevada contractor's license number issued by the State Contractor's Board 0035901  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916  
 Signed Larry Jenkins  
 By driller performing actual drilling on site or contractor  
 Date 6-25-96

